



TOWN OF LYNNFIELD
DEPARTMENT OF PUBLIC WORKS

TOWN HALL
55 SUMMER STREET
LYNNFIELD MA 01940-1843

JOHN M. TOMASZ, DIRECTOR
PATRICK MCALPINE, P.E.

PHONE: 781-334-9500
FAX: 781-334-9509

11/02/2022

Planning Board Members:

I have reviewed the response to comments from Peter Ogren dated October 17th 2022 in regards to the proposed sub-division known as Vallis Way. I have also reviewed the comments from Linden Engineering dated October 26th 2022. As the town engineer, all my comments have been addressed, under the following explanations / understandings:

1. National Grid does not see a feasible way to supply gas to this sub division.
2. The stormceptor should be moved to the side of the road to prevent multiple inflows and is able to handle a 100 year rain event.
3. There is no objection to using HDPE perforated pipe in the infiltration run, as long as all other pipe in the drainage system is RCP, as called for on the plan.
4. The town engineer, in conjunction with Linden Engineering, should be onsite for final inspection of all infiltration systems.

Sincerely,

Patrick McAlpine PE
Town Engineer
Lynnfield DPW